

BRE Global Ireland

Notified Body No. 2831
BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

Certificate of approval constancy of performance 2831-CPR-F4899

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s).

D1xB2X05DC024*A1R/R Conventional Type B Xenon Strobe VAD (Red Enclosure – Red Lens)**

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trademark of: and produced in the manufacturing plant(s):

European Safety Systems Ltd
Impress House
Mansell Road
London
W3 7QH
United Kingdom

European Safety Systems Ltd
Impress House
Mansell Road
London
W3 7QH
United Kingdom

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-23:2010 - Visual alarm devices

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 05 September 2023 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



P Halligan, Certification Engineer

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 05 September 2023

Issue Date: 05 September 2023

Issue Number: 01

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email enquiries@breglobalireland.ie

BRE Global Ireland

Approved Body No. 2831
BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

APPENDIX to Certificate of constancy of performance: 2831-CPR-F4899**D1xB2X05DC024***A1R/R Conventional Type B Xenon Strobe VAD (Red Enclosure – Red Lens)****Notes:**

1. Meets the requirements of EN 54-23 at the following:
 - Category rating C-3-2.92 + W-2.4-1.3 + Open
 - Flash rate 1Hz
 - Flash Colour Red
 - For wall and ceiling mounting using integral feet

Variants:

- D1xB2X05DC024***ATR/R (Red Enclosure - Red Lens - Tropicalised)
- D1xB2X05DC024***A1G/R (Grey Enclosure - Red Lens)
- D1xB2X05DC024***ATG/R (Grey Enclosure - Red Lens - Tropicalised)



P Halligan, Certification Engineer

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 05 September 2023

Issue Date: 05 September 2023

Issue Number: 01

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie