

DECLARATION OF PERFORMANCE



Manufacturer: European Safety Systems Ltd.
Impress House, Mansell Road, Acton
London, W3 7QH, UK

Equipment Type: A100DC024, A105NDC024 Electronic Sounder

Intended Use: Fire Safety (Fire Detection and Fire Alarm Systems – Alarm Devices – Sounders, buildings)

System of Assessment and Verification of Constancy of Performance: 1

Notified Body for EC type Examination and Factory Production Control: UL International (Netherlands) B.V.
Notified Body No.: 2821
Westervoortsedijk 60 6827 AT ARNHEM Netherlands

EC-type Examination Certificate: 2821-CPR-0107

Notified Body for UKCA Examination and Factory Production Control: UL International (UK) Ltd.
Notified Body No.: 0843
Unit 1-3 Horizon Kingsland Business Park, Wade Road,
Basingstoke, Hampshire RG24 8AH UK

UKCA Examination Certificate: 0842-CPR-1005

Standards: EN 54-3:2001 / A1:2002 / A2:2006
Units tested to EN 54-3:2014 / A1:2019

Declared Performance:

Essential Characteristics	Performance	Standard
Performance parameters under fire conditions <ul style="list-style-type: none"> - Sound level - Frequencies and sound pattern - Reproducibility - Operational Performance - Attention drawing signal and message broadcast sequences - Synchronisation - Broadcast message performance - Attention drawing signal/silence/message sequence timing - Message synchronisation testing 	<ul style="list-style-type: none"> Pass Pass Pass Pass Not applicable Not applicable Not applicable Not applicable 	<ul style="list-style-type: none"> EN 54-3:2001 / A1:2002 / A2:2006 Clause 4.2 Clause 4.3 Clause 5.2 Clause 5.3 Clause C.3.1 Clause C.3.2 Clause C.5.1 Clause C.5.2 Clause C.5.3
Operational reliability <ul style="list-style-type: none"> - Durability - Construction - Marking and data - Durability - General testing 	<ul style="list-style-type: none"> Pass Pass Pass Pass Not applicable 	<ul style="list-style-type: none"> EN 54-3:2001 / A1:2002 / A2:2006 Clause 4.4 Clause 4.5 Clause 4.6 Clause 5.4 Clause C.4
Durability of operational reliability, temperature resistance <ul style="list-style-type: none"> - Dry heat (operational) - Dry heat (endurance) - Cold (operational) - Damp heat. Cyclic (operational) Damp heat, steady state (endurance) Durability of operational reliability, humidity resistance <ul style="list-style-type: none"> - Damp heat, cyclic (operational) - Damp heat, steady state (endurance) - Damp heat, cyclic (endurance) Durability of operational reliability, corrosion resistance <ul style="list-style-type: none"> - Sulphur dioxide (SO₂) corrosion (endurance) Durability of operational reliability, shock and vibration resistance <ul style="list-style-type: none"> - Shock (operational) - Impact (operational) - Vibration, sinusoidal (operational) - Vibration, sinusoidal (endurance) Durability of operational reliability, electrical stability <ul style="list-style-type: none"> - Electromagnetic compatibility (EMC), immunity (operational) Durability of operational reliability, resistance to ingress <ul style="list-style-type: none"> - Enclosure protection 	<ul style="list-style-type: none"> Pass Pass Pass Pass Pass Pass Pass Pass Pass Pass Pass Pass Pass Pass Pass Pass Pass Pass 	<ul style="list-style-type: none"> EN 54-3:2001 / A1:2002 / A2:2006 Clause 5.5 Clause 5.6 Clause 5.7 Clause 5.8 Clause 5.9 Clause 5.8 Clause 5.9 Clause 5.10 Clause 5.11 Clause 5.12 Clause 5.13 Clause 5.14 Clause 5.15 Clause 5.16 Clause 5.17

DECLARATION OF PERFORMANCE



Manufacturer: European Safety Systems Ltd.
Impress House, Mansell Road, Acton
London, W3 7QH, UK

The performance of the product identified above is in conformity with the declared performance. This declaration of performance is issued under the sole responsibility of the manufacturer identified above.

A handwritten signature in black ink, appearing to read 'Martin Streetz', written over a light blue horizontal line.

Martin Streetz
Quality Assurance Manager

Date and Place of Issue: London, 22/06/2021
Document No: 2821-CPR-0107
Issue: C