
Certificate of Test Conformance Number: 104611 Issue 2

Customer Name & Address: European Safety Systems Ltd (e2s)
Impress House
Mansell Road
London
W3 7QH

Customer Order Number: PO29987ESS

Test Item Receipt Date: 22nd June 2022

Test Item Description: Sounders & Loudspeakers Beacons & Junction Boxes

Test Item Part Number: GNExS & GNExL GNExB & GNExJ

Test Item Serial Number: 1 to 3 1, 3 and 4

Test Item Quantity: 3 3

Reference Standard: BS EN 60529: 1992 + A2: 2013:
Degrees of Protection Provided by Enclosures

Applied Test: IP66, IP67

Test Date: 28th June to 8th July 2022

Test Results: The detailed tests were performed in accordance with the defined environmental test standard.

All enclosures conformed to the requirements of the IP66 and IP67 rating.

Author:



Kia Tabrizi
Test Lab Engineer

Approval:



Paul Lee
Test Lab / Quality Manager

Issue Date:

22nd July 2022

*The results detailed herein relate only to the test item(s) submitted for testing.
Opinions and interpretations expressed herein are outside the scope of UKAS accreditation.*

Certificate of Test Conformance Number: 104611 Issue 2

Additional Information

Revision Level	Summary of Changes
1	Initial Release
2	Product description changed from "Sounder" and "Beacon" to "Sounders & Loudspeakers" and "Beacons & Junction Boxes"

END OF CERTIFICATE
