

CERTIFICATE OF COMPLIANCE

Certificate Number 20150707-E230764
Report Reference E230764-20150702
Issue Date 2015-JULY-07

Issued to: European Safety Systems Ltd
Units 18 & 20, Impress House
MANSELL ROAD, ACTON
London
W3 7QH UNITED KINGDOM

**This is to certify that
representative samples of**

AUDIBLE-SIGNAL APPLIANCES FOR USE IN
HAZARDOUS LOCATIONS, AUDIBLE-SIGNAL
APPLIANCES FOR USE IN ZONE CLASSIFIED
HAZARDOUS LOCATIONS

Class I, Division 1, Groups A, B, C and D Hazardous
Locations; Loudspeakers: Model number D1x, followed by
L1 or L2, followed by -, followed by V070, R008 or R016.
Class II, Division 1, Groups F and G Hazardous Locations.
Loudspeakers: Model number D1x, followed by L1 or L2,
followed by -, followed by V070, R008 or R016. Followed by
-D.


Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: See next page for standards.

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20150707-E230764
Report Reference E230764-20150702
Issue Date 2015-JULY-07

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

UL 1203, Explosion-Proof and Dust-Ignition-Proof Electrical Equipment for Use in Hazardous (Classified) Locations


CAN/CSA C22.2 No. 25-1966, Enclosures for Use in Class II Groups E, F, and G Hazardous Locations

CSA C22.2 NO. 30-M1986, Explosion Proof Enclosures for use in Class I Hazardous Locations

CSA C22.2 NO. 205-12 Signal Equipment

UL 1480, Speakers for Fire Alarm, Emergency, and Commercial and Professional use

UL 50E Enclosures for Electrical Equipment, Environmental Considerations



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

