

CERTIFICATE OF COMPLIANCE

Certificate Number 20180523-E496070
Report Reference E496070-20180521
Issue Date 2018-MAY-23

Issued to: European Safety Systems Ltd
Units 18 & 20, Impress House
MANSELL ROAD, ACTON
London
W3 7QH UNITED KINGDOM

**This is to certify that
representative samples of**

SIGNALING APPLIANCES AND EQUIPMENT FOR THE
HEARING IMPAIRED FOR USE IN HAZARDOUS
LOCATIONS

Refer to addendum page for Models/Product

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.


Standard(s) for Safety:
Additional Information:

Refer to addendum page for Standard(s).

See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20180523-E496070
Report Reference E496070-20180521
Issue Date 2018-MAY-23

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.


Models/Product

Visual signal devices, Models D1xB2XH1DC024 and D1xB2XH2DC024, each may be followed by up to four non certification specific alphanumeric characters for use in:

USL/CNL Class I Division 1 Groups A, B, C and D;
Class II Division 1 Groups E, F and G; and
Class III; Hazardous Locations

Additional Information for Marking:

- By Equivalency, the equipment may be additionally marked:
Class I Zone 1 AEx db IIC1 Tx*
Ex db IIC1 Tx*
(1 - may also be marked IIB or IIA, Tx* - represents appropriate Tcode)
- By Equivalency, the equipment may be additionally marked:
Zone 21 / 22 AEx tb IIIC2 Txx°C*
Ex tb IIIC2 Txx°C*
(2 - may also be marked IIIB or IIIA, Txx°C* - represents appropriate Temperature)
Zone 21 / 22 as appropriate.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>.



CERTIFICATE OF COMPLIANCE

Certificate Number 20180523-E496070
Report Reference E496070-20180521
Issue Date 2018-MAY-23

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Models/Product

Standard(s) for Safety:

Standard No. UL 1203, 5th Ed., Rev. 2015-10-16, Explosion-Proof and Dust-Ignition-Proof Electrical Equipment for Use in Hazardous (Classified) Locations

Standard No. CAN/CSA C22.2 No. 30-M1986, 3rd Ed., Issued 1986-11 + General Instruction No. 2:1988-11, Explosion-Proof Enclosures for Use in Class I Hazardous Locations

Standard No. CSA C22.2 No. 25-17, Issued 2017-07, Enclosures for Use in Class II Groups E, F, and G Hazardous Locations

UL 50 ENCLOSURES FOR ELECTRICAL EQUIPMENT, NON-ENVIRONMENTAL
CONSIDERATIONS- Edition 12 - Revision Date 2012/04/27

UL 50E ENCLOSURES FOR ELECTRICAL EQUIPMENT, ENVIRONMENTAL CONSIDERATIONS-
Edition 2 - Issue Date 2015/10/16


CSA C22.2 NO. 94.1.15 ENCLOSURES FOR ELECTRICAL EQUIPMENT, NON-ENVIRONMENTAL
CONSIDERATIONS- Edition 2 - Issue Date 2015/10/01

CSA C22.2 NO. 94.2-15 ENCLOSURES FOR ELECTRICAL EQUIPMENT, ENVIRONMENTAL
CONSIDERATIONS- Edition 2 - Issue Date 2015/10/16

UL 1638, Visible Signaling Devices for Fire Alarm and Signaling Systems, Including Accessories, Fifth
Edition, dated Jan 28, 2016

CAN/ULC-S526-16, Visible Signaling Devices for Fire Alarm and Signaling Systems, Including
Accessories, Fourth Edition, dated Jan 28, 2016

UL 1971 STANDARD FOR SIGNALING DEVICES FOR THE HEARING IMPAIRED- Edition 3 -
Revision Date 2013/10/31



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

