

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 7125-2279:0507

Page 1 of 1

**CATEGORY:** 7125 -- FIRE ALARM DEVICES FOR THE HEARING IMPAIRED

**LISTEE:** European Safety Systems LTD Units 18 & 20, Impress House, Mansell Road, Acton, London, W3 7QH, GB United Kingdom  
Contact: Alan King 44 20 8743 8880  
Email: alan.king@e2s.com

**DESIGN:** Models D1xB2XH1DC024 and D1xB2XH2DC024 Visual signal devices, each may be followed by up to four non certification specific alphanumeric characters for use in:  
Class I Division 1 Groups A, B, C and D;  
Class II Division 1 Groups E, F and G; and  
Class III; Hazardous Locations

The visual signal devices (beacon devices) are for use in Hazardous Locations for Public mode functions. One enclosure design is consistent throughout the series with different PCB designs to cater for the various light outputs. The beacon devices employ a glass len. The light source is a xenon lamp assembly.

Refer to listee's printed data sheet for additional detailed product description and operational considerations.

**RATING:** Refer to listee's printed datasheet for electrical and environmental ratings.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating, and UL label.

**APPROVAL:** Listed as visual devices for the hearing impaired for use in hazardous locations when used with separately listed compatible fire alarm control units. The devices are intended for indoor or outdoor installation.

08-07-18 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2020**

Listing Expires **June 30, 2021**

Authorized By: **DAVID CASTILLO, M.E., F.P.E.**  
*Fire Engineering Division*