

UL-EU CERTIFICATE

Certificate No. UL-EU-01154-CPR

Page 1/3

Date of Issue 2021-04-16

Certificate Holder European Safety Systems Ltd
Units 18 & 20, Impress House
Mansell Road Action
London, W3 7QH, UK

Manufacturer As per certificate holder

Certified Product Type Fire Alarm Devices - Sounder - Type B (outdoor)
Alarm Devices - Visual Alarm Device - Type B (outdoor)

Product Trade Name AlertAlarm Range
Models: AL100XDC024, AL105NXDC024, AL100XDC048,
and AL105NXDC048

Trademark



Rating/Classification AL100XDC024 / AL105NXDC024: 24 V dc
(20.0 – 28.0 V dc)

AL100XDC048 / AL105NXDC048: 48 V dc
(42.0 – 52.0 V dc)

Certified Tones: Tone 2: Fainting Tone, 1200/500Hz @1Hz
Tone 5: Alternating Tone, 544Hz(100mS)/440Hz (400mS)
Tone 8: Rising Tone, 500/1200Hz @ 0.26Hz (3.3s on, 0.5s off)
Tone 21: Continuous Tone, 800Hz
Tone 31: Pulsed Tone, 660Hz (150mS on, 150mS off)
Tone 44: Alternating Tone 800/1000Hz @ 2Hz Alternating

A handwritten signature in blue ink, appearing to read 'Chris Miles'.

Authorized Certification Decision Maker

Chris Miles

This is to certify that representative samples of the Certified Product listed above have been investigated by Underwriters Laboratories to the Standard(s) indicated on this Certificate, in accordance with the UL Global Services Agreement and the UL-EU Mark Service Terms and Conditions ("Agreement"). The Certificate Holder is entitled to use the UL-EU Mark for the Certified Product listed on the certificate and manufactured at the production site(s) listed, in accordance with the terms of the Agreement. Only those products bearing the UL-EU Mark for Europe should be considered as being covered by UL's UL-EU Mark Service. This Certificate shall remain valid through the Expiration date, unless a Standard identified on this Certificate is amended or withdrawn prior to that date or there is a non-compliance with the Agreement.



UL-EU Certificate

Certification Mark UL-EU mark
Certificate No. UL-EU-01154-CPR
Page 2/3
Date of Issue 2021-04-16

Approved Beacon Applications: Lens Colour – Clear
Flash Mode – 1 Hz
Position – Sounder on top, beacon below

Category: W (Wall)

Coverage Area: AL100XDC024 / AL105NXDC024 @ 24 V dc:
W-2.4-4.8; Power = 7 Watts

AL100XDC048 / AL105NXDC048 @ 48 V dc:
W-2.5-5.0; Power = 11 Watts

Coverage Volume: AL100XDC024 / AL105NXDC024 @ 24 V dc:
 $V = 55.3^3$

AL100XDC048 / AL105NXDC048 @ 48 V dc:
 $V = 62.5^3$

Harmonised Technical Specifications EN 54-3:2001 + A1:2002 + A2:2006 – Sounders
EN 54-3:2014 + A1:2019 – Sounders
EN 54-23:2010 – Visual alarm devices

Descriptive Report S36282-D01-EuropeanDirective-Original
Expiry date 2031-04-15



Appendix UL-EU Certificate

Certification Mark	UL-EU mark
Certificate No.	UL-EU-01154-CPR
Page	3/3
Date of Issue	2021-04-16

The UL-EU Mark, as displayed below, shall appear on certified products only. Minimum size is not specified, as long as the Mark is legible. The following is suggested.



The minimum height of the registered trademark symbol ® shall be 1 mm. When the overall diameter of the UL-EU Mark is less than 9.5 mm, the trademark symbol may be omitted if it is not legible to the naked eye.

The UL-EU Mark may appear on a label, nameplate, or may be cast, stamped or molded into the product. When appearing on a label or nameplate, the Manufacturer's name or trademark along with a model number are also required on that same label or nameplate. If cast, stamped or molded, the Manufacturer's name or trademark and model number shall also appear elsewhere on the product.

All content shall be in accordance with the details provided on this UL-EU Certificate.

PROCUREMENT

The Production site may reproduce the Mark or obtain it from a UL authorized supplier. The list of UL authorized suppliers can be found on UL's online directory at www.ul.com.

