

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7151-2279:0509 Page 1 of 1

CATEGORY: 7151 -- BOXES/PULL STATIONS-HAZARDOUS LOCATIONS

LISTEE: European Safety Systems LTD Units 18 & 20, Impress House, Mansell Road, Acton, London, W3 7QH, GB United Kingdom
Contact: Alan King 44 20 8743 8880
Email: alan.king@e2s.com

DESIGN: Models GNExCP7-, followed by PB-, PM-, or PT-, followed by S or D, Flameproof Call Point Enclosures. Units are manual push buttons, single or dual switch, with the flameproof enclosure constructed of natural, glass reinforced polymer.

Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 24 Vdc, 48 Vdc, or 250 Vac

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, rating, and UL label.

APPROVAL: Listed as manual push buttons for use with separately listed compatible fire alarm control units. Suitable for indoor or outdoor use and in Class I, Division 2, Group A, B, C, D, T6; Class II, Division 2, Group F, G, T4; and Class III, Division 1 and 2 hazardous locations. Refer to listee's Installation Instruction Manual for details.

11-25-20 VWW



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2021**

Listing Expires **June 30, 2022**

Authorized By: **DAVID CASTILLO, M.E., F.P.E.**
Fire Engineering Division