



EC CERTIFICATE

NOTIFIED BODY NUMBER 2821

CERTIFICATE OF CONSTANCY OF PERFORMANCE CERTIFICATE No. 2821-CPR-0108

This is to certify that UL International (Netherlands) B.V. did undertake the relevant AVCP procedures for the equipment identified below which was found to be in compliance with the Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product, subject to any conditions attached hereto.

Manufacturer: European Safety Systems Ltd

Address: Units 18 & 20, Impress House, Mansell Road Action, London W3 7QH, UK

Product Description: Fire Alarm Devices - Sounder

Model Reference: AlertAlarm Range, A112N and A121 Sounders
Models A112NDC024 and A121DC024

Places of production: Same as manufacturer

Harmonised Standard(s): EN 54-3:2001 + A1:2002 + A2:2006

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the above referenced standards, under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate will remain valid as long as neither the standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Date of 1st issue: 16th April 2021
Issue: 1
Date of re-issue: N/A

Signed:

Issued by UL International (NL) B.V. Notified Body 2821.

Name: Koen Schilleman
Deputy Head of Notified Body

EC CERTIFICATE

Schedule for certificate No. 2821-CPR-0108

Detailed information sheet

Model Reference: AlertAlarm Range, A112N - Model A112NDC024
Type: Type B (Outdoor)
Description: Fire Alarm Devices - Sounder
Voltage: 24 / 48 V dc (11.5 - 54 V dc)

Certified Tones:
Tone 2: Fainting Tone, 1200/500Hz @1Hz
Tone 5: Alternating Tone, 544Hz(100mS)/440Hz (400mS)
Tone 8: Rising Tone, 500/1200Hz @ 0.26Hz (3.3s on, 0.5s off)
Tone 21: Continuous Tone, 800Hz
Tone 31: Pulsed Tone, 660Hz (150mS on, 150mS off)
Tone 44: Alternating Tone 800/1000Hz @ 2Hz Alternating

Model Reference: AlertAlarm Range, A121 - Model A121DC024
Type: Type B (Outdoor)
Description: Fire Alarm Devices - Sounder
Voltage: 24 / 48 V dc (16 - 54 V dc)

Certified Tones:
Tone 2: Fainting Tone, 1200/500Hz @1Hz
Tone 5: Alternating Tone, 544Hz(100mS)/440Hz (400mS)
Tone 8: Rising Tone, 500/1200Hz @ 0.26Hz (3.3s on, 0.5s off)
Tone 21: Continuous Tone, 800Hz
Tone 31: Pulsed Tone, 660Hz (150mS on, 150mS off)
Tone 44: Alternating Tone 800/1000Hz @ 2Hz Alternating

Technical documentation:

UL Report: S36282-D02-EuropeanDirective-Original

Limitations on the acceptance or use of the product(s):

Installation instructions To be used in accordance with the supplier's installation instructions.

Terms and Conditions:

1. This certificate remains the property of UL International (NL) B.V, herein "UL NL", and will be withdrawn if any conditions attached to its issue are not complied with.
2. This certificate is issued subject to the Global Services Agreement (GSA) and CPR Service Terms.
3. Production is limited to the site(s) as listed, or detailed within the Technical documentation held by UL NL.
4. Any product change, production/process changes, etc. which may affect conformity shall be notified to UL NL.
5. This certificate is only valid for placing goods on the EU market.

END OF CERTIFICATE

Date of 1st issue: 16th April 2021
Issue: 1
Date of re-issue: N/A

Signed:



Issued by UL International (NL) B.V. Notified Body 2821.

Name: Koen Schilleman
Deputy Head of Notified Body

Page 2 of 2