
Certificate of Test Conformance Number: 104531 Issue 2

Customer Name & Address: European Safety Systems Ltd (e2s)
Impress House
Mansell Road
London
W3 7QH

Customer Order Number: 29290ESS, 29472ESS

Test Item Receipt Date: 21st February 2022

Test Item Description: STExCP8 Callpoint

Test Item Part Number: STExCP8BG STExCP8PM

Test Item Serial Number: Sample 1 Sample 3

Test Item Quantity: 1 1

Reference Standard: BS EN 60529: 1992 + A2: 2013:
Degrees of Protection Provided by Enclosures

Applied Test: IPx7

Test Date: 8th and 17th March 2022

Test Results: The detailed test was performed in accordance with the defined environmental test standard.

Both enclosures conformed to the requirements of the IPx7 rating.

Additional Variants:

The customer has confirmed that the enclosure design and sealing properties of the tested items are shared across the following STEx Callpoint range:

STExCP8PM – Momentary Push button
STExCP8PT – Tool reset Push button
STExCP8PB – Dual Action Push button

Author:



Kia Tabrizi
Test Lab Engineer

Approval:



Paul Lee
Test Lab Manager

Issue Date:

31st March 2022

*The results detailed herein relate only to the test item(s) submitted for testing.
Opinions and interpretations expressed herein are outside the scope of UKAS accreditation.*

Certificate of Test Conformance Number: 104531 Issue 2

Additional Information

Revision Level	Summary of Changes
1	Initial release
2	Additional Variants added
