

# CERTIFICATE OF COMPLIANCE

**Certificate Number** E230764  
**Report Reference** E230764-20150818  
**Date** 2022-January-20

**Issued to:** European Safety Systems Ltd  
Impress House  
Mansell Rd.  
London W3 7QH GB

**This is to certify that representative samples of** AUDIBLE-SIGNAL APPLIANCES FOR USE IN HAZARDOUS LOCATIONS  
See Addendum Page for Product Designation(s).

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.


**Standard(s) for Safety:** See Addendum Page for Standards.

**Additional Information:** See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information

This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



# CERTIFICATE OF COMPLIANCE

**Certificate Number** E230764  
**Report Reference** E230764-20150818  
**Date** 2022-January-20

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

**Models:**

Class I, Division 1, Groups A, B, C and D Hazardous Locations;

**Sounders, general signalling:**

Models D1xS1-DC024-A, D1xS1-DC024-S, D1xS1-AC230-A, D1xS2-DC024-A, D1xS2-DC024-S and D1xS2-AC230-A.

**Sounders, public mode:**

Models D1xS1-DC024-A, D1xS1-DC024-S, D1xS2-DC024-A and D1xS2-DC024-S.

**Combined Sounder Beacons, general signalling (all lens color):**

Models D1xC1X05-DC024-A, D1xC1X05-AC115-A, D1xC1X05-AC230-A, D1xC2X05-DC024-A, D1xC2X05-AC115-A, D1xC2X05-AC230-A, D1xC1X10-DC024-A, D1xC1X10-AC115-A, D1xC1X10-AC230-A, D1xC2X10-DC024-A, D1xC2X10-AC115-A and D1xC2X10-AC230-A. These devices are suitable only in the specific atmospheres indicated in the manufacturer's instruction manual document D190-00-xxx-IS-SC, where xxx is the 3 digits to the relevant instruction manual document, supplied with each device.

**Combined Sounder Beacons, public mode sounder, private mode beacon (clear lens only):**

Models D1xC1X05-DC024-A, D1xC2X05-DC024-A, D1xC1X10-DC024-A and D1xC2X10-DC024-A. These devices are suitable only in the specific atmospheres indicated in the manufacturer's instruction manual document D190-00-xxx-IS-SC, where xxx is the 3 digits to the relevant instruction manual document, supplied with each device.


Class II, Division 1, Groups F and G Hazardous Locations.

**Sounders, general signalling:**

Models D1xS1-DC024-D, D1xS1-AC230-D, D1xS2-DC024-D and D1xS2-AC230-D.

**Combined Sounder Beacons, general signalling:**

Models D1xC1X05-DC024-D, D1xC1X05-AC115-D, D1xC1X05-AC230-D, D1xC2X05-DC024-D, D1xC2X05-AC115-D and D1xC2X05-AC230-D.



Bruce Mahrenholz, Director North American Certification Program

UL LLC



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

# CERTIFICATE OF COMPLIANCE

**Certificate Number** E230764  
**Report Reference** E230764-20150818  
**Date** 2022-January-20

**Standards:**

UL 1203, ExplosionProof and Dust-IgnitionProof Electrical Equipment for Use in Hazardous (Classified)

**Locations**

CSA C22.2 No. 30, Explosion-proof equipment

CSA C22.2 No. 25, Enclosures for Use in Class II Groups E, F, and G Hazardous Locations

UL 464, Audible Signaling Devices for Fire Alarm and Signaling Systems, Including Accessories

CAN/ULC-S525, Audible Signaling Devices for Fire Alarm and Signaling Systems, Including Accessories


UL 1638, Visible Signaling Devices for Fire Alarm and Signaling Systems, Including Accessories

CAN/ULC-S526, Visible Signaling Devices for Fire Alarm and Signaling Systems, Including Accessories

UL 464A, Audible Signal Appliances for General Signaling Use

UL 1638A, Visual Signal Appliances for General Signaling Use

C22.2 No. 205-17, Signal Equipment



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

