



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	7125-2279:0507
CATEGORY:	7125 - FIRE ALARM DEVICES FOR THE HEARING IMPAIRED
LISTEE:	European Safety Systems LTD Units 18 & 20, Impress House, Mansell Road, Acton, London, , W3 7QH, GB Contact: King,Alan Email: alan.king@e2s.com
DESIGN:	<p>Models D1xB2XH1DC024 and D1xB2XH2DC024 Visual signal devices, each may be followed by up to four non certification specific alphanumeric characters for use in:</p> <p>Class I Division 1 Groups A, B, C and D; Class II Division 1 Groups E, F and G; and Class III; Hazardous Locations</p> <p>The visual signal devices (beacon devices) are for use in Hazardous Locations for Public mode functions. One enclosure design is consistent throughout the series with different PCB designs to cater for the various light outputs. The beacon devices employ a glass len. The light source is a xenon lamp assembly.</p> <p>Refer to listee's printed data sheet for additional detailed product description and operational considerations.</p>
RATING:	Refer to listee's printed datasheet for electrical and environmental ratings.
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, electrical rating, and UL label.
APPROVAL:	Listed as visual devices for the hearing impaired for use in hazardous locations when used with separately listed compatible fire alarm control units. The devices are intended for indoor or outdoor installation.
NOTES:	

08-07-18 gt



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 04/19/2022

Listing Expires: 06/30/2023

Authorized By: **Victor Wong**, Program Coordinator
Fire Engineering & Investigations Division