

CERTIFICATE OF COMPLIANCE

Certificate Number E245313
Report Reference E245313-20171013
Date 2022-April-01

Issued to: European Safety Systems Ltd
Impress House
Mansell Rd.
London W3 7QH GB

**This is to certify that
representative samples of**

VISUAL-SIGNAL APPLIANCES FOR USE IN
HAZARDOUS LOCATIONS

See Addendum Page for Product Designation(s).

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.


Standard(s) for Safety: See Addendum Page for Standard(s).

Additional Information: See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information

This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number E245313
Report Reference E245313-20171013
Date 2022-April-01

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

Product(s):

Visual signal devices, Models D2xB1LD2DC024, D2xB1LD2AC115, D2xB1LD2AC230, D2xB1LD3DC024, D2xB1X05DC024, D2xB1X05DC048, D2xB1X05AC115, D2xB1X05AC230, D2xB1X10DC024, D2xB1X10DC048, D2xB1X10AC115, D2xB1X10AC230, D2xB1XH1DC024 and D2xB1XH2DC024, each may be followed by up to four non certification specific alphanumeric characters, and Accessories, Models D2xJ1T and D2xJ1D, each may be followed by up to four non certification specific alphanumeric characters, each may be followed by up to four non certification specific alphanumeric characters for use in:

USL Class I, Division 2, Groups A, B, C and D;
Class II, Division 2, Groups F and G; Class III; Hazardous Locations


Class I Zone 2 AEx ec IIC Gc;
Zone 22 AEx tc IIIC Dc; Hazardous Locations.

CNL Class I, Division 2, Groups A, B, C and D;
Class II, Division 2, Groups F and G; Class III; Hazardous Locations

Ex ec IIC Gc X;
Ex tc IIIC Dc X; Hazardous Locations.

Standard(s) for Safety:

UL 121201, Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations
CSA C22.2 No. 213-17, Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations
UL 60079-0, Explosive Atmospheres - Part 0: Equipment - General Requirements
CSA C22.2 No. 60079-0, Electrical Apparatus for Explosive Gas Atmospheres - Part 0: General Requirements
UL 60079-7, Explosive atmospheres - Part 7: Equipment protection by increased safety
CSA C22.2 No. 60079-7, Explosive Atmospheres - Part 7: Equipment Protection by Increased Safety
UL 60079-31, Explosive Atmospheres - Part 31: Equipment Dust Ignition Protection by Enclosure
CSA C22.2 No. 60079-31, Explosive Atmospheres - Part 31: Equipment Dust Ignition Protection by Enclosure
UL 1638, Visible Signaling Devices for Fire Alarm and Signaling Systems, Including Accessories
UL 1638A, Visual Signal Appliances for General Signaling Use
UL 1971, Signaling Devices for the Hearing Impaired
CSA C22.2. No. 205, Signal Equipment
CAN/ULC-S526-16, Visible Signaling Devices for Fire Alarm and Signaling Systems, Including Accessories
CSA C22.2 NO. 94.2-15 Enclosures for electrical equipment, environmental considerations- Edition 2 - Issue Date 2015/10/16



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

