


1	2	3	4	5	6	7	8	9	10
							ISSUE	MOD No.	REASON - INITIAL - DATE
OPTIONAL LINE MONITORING RESISTOR, CUSTOMER SUPPLIED, MINIMUM VALUES: 500Ω MIN, 2W MIN OR 3K3Ω MIN, 0.5W MIN							SWITCHES FOR STAGE OPERATION CUSTOMER SUPPLIED		WIRING LINKING BEACON & SOUNDER FACTORY FITTED
							1		INTRODUCTION RSR - 05/09/2022
							2		AMENDED LINKING WIRES RSR - 24/11/2023

Single Stage Configuration	Config.: 1a	Two Stage Configuration	Config.: 1b	Three Stage Configuration	Config.: 1c
Line Monitoring Set to negative switching (default)		Common Positive Set to negative switching (default)		Common Negative Set to positive switching (Customer to set header pin)	
Stage 1: Apply Power to Stage 1 +ve & Stage 1 -ve		Stage 1: Apply Power to +ve & -ve Stage 2: Apply Power to +ve & -ve, Connect Stage 2 to -ve Stage 3: Apply Power to +ve & -ve, Connect Stage 3 to -ve		Stage 1: Apply Power to +ve & -ve Stage 2: Apply Power to +ve & -ve, Connect Stage 2 to +ve Stage 3: Apply Power to +ve & -ve, Connect Stage 3 to +ve	



DRAWING TO BS8888:2000 GEOMETRIC TOLERANCES TO ISO1101:1983 LINEAR DIMENSIONAL TOLS ANGULAR DIMENSIONAL TOLS	DRAWN	DATE	SURFACE FINISH	WEIGHT (Kg)	THIS DRAWING AND ANY INFORMATION OR DESCRIPTIVE MATTER THEREIN IS COMMUNICATED IN CONFIDENCE AND IS THE COPYRIGHT PROPERTY OF EUROPEAN SAFETY SYSTEMS LTD. NEITHER THE WHOLE OR ANY EXTRACT MAY BE DISCLOSED, LOANED, COPIED OR USED FOR MANUFACTURING OR TENDERING PURPOSES WITHOUT THEIR WRITTEN CONSENT.	warning signals EUROPEAN SAFETY SYSTEMS LTD IMPRESS HOUSE MANSELL ROAD ACTON LONDON W3 7QH WWW.E2S.COM	ALL DIMENSIONS IN MM IF IN DOUBT, ASK - DO NOT SCALE		A3
	R.S.RAIT	08/03/2022					MATERIAL		
	CHECKED	DATE	ALTERNATIVE MATERIAL				TITLE BExCS110-05D DC COMBINED SOUNDER & BEACON WIRING DIAGRAMS		
	B.ISARD	08/03/2022					SCALE	SHEET	DRAWING NUMBER
STANDARDS	APPROVED	DATE			NTS	1 OF 1	D210-06-601		
BEx	R.N.POTTS	08/03/2022							