

CERTIFICATE OF COMPLIANCE

Certificate Number E482536
Report Reference E482536-20190529
Date 2022-August-09

Issued to: European Safety Systems Ltd
Impress House
Mansell Rd.
London W3 7QH GB

**This is to certify that
representative samples of**

FIRE ALARM DEVICES FOR USE IN ZONE CLASSIFIED
HAZARDOUS LOCATIONS

See Addendum Page for Product Designation(s).

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.


Standard(s) for Safety: See Addendum Page for Standard(s)

Additional Information: See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information

This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number E482536
Report Reference E482536-20190529
Date 2022-August-09

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

USL, Fire Alarm Box, GNEEx Series Call Point, Model(s) GNEExCP7-, followed by BG- or PT-, followed by S or D; for use in Class I Zone 1 AEx db IIC Gb and Zone 21 AEx tb IIIC Db, Hazardous Locations.


CNL, Fire Alarm Box, GNEEx Series Call Point, Model(s) GNEExCP7-, followed by BG- or PT-, followed by S or D; for use in Ex db IIC Gb and Ex tb IIIC Db, Hazardous Locations.

The following equivalency markings may also be marked on the equipment:

Class I, Division 2, Group A, B, C, D, T5
Class I, Division 2, Group A, B, C, D, T6
Class II Division 2, Group F, G, T4
Class III Division 2

“Class” may be abbreviated to “Cl”
“Division” may be abbreviated to “Div”

Standard	Title	Edition	Revision Date
UL 60079-0	EXPLOSIVE ATMOSPHERES - PART 0: EQUIPMENT - GENERAL REQUIREMENTS,	7	2020-04-15
UL 60079-1	EXPLOSIVE ATMOSPHERES - PART 1: EQUIPMENT PROTECTION BY FLAMEPROOF ENCLOSURES 'D'	7	2015-09-18
UL 60079-31	EXPLOSIVE ATMOSPHERES - PART 31: EQUIPMENT DUST IGNITION PROTECTION BY ENCLOSURE "T"	2	2015-06-12
UL 38	STANDARD FOR MANUAL SIGNALING BOXES FOR FIRE ALARM SYSTEMS	8	2018-09-04
CSA C22.2 No. 60079-0	ELECTRICAL APPARATUS FOR EXPLOSIVE GAS ATMOSPHERES - PART 0: GENERAL REQUIREMENTS	4	2019-02
CSA C22.2 No. 60079-1	ELECTRICAL APPARATUS FOR EXPLOSIVE GAS ATMOSPHERES – PART 1: FLAMEPROOF ENCLOSURES 'D'	3	2016-05-01 (Reaffirmed 2021)
CSA C22.2 No. 60079-31	EXPLOSIVE ATMOSPHERES - PART 31: EQUIPMENT DUST IGNITION PROTECTION BY ENCLOSURE "T"	2	2015/10
CAN/ULC S528	MANUAL STATIONS FOR FIRE ALARM SYSTEMS, INCLUDING ACCESSORIES	3	2014-10-01



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



Certificate of Compliance

Certificate Number:

UL-US-L513632-352311-42200202-2

Report Reference:

E513632-20200224

Issue Date:

2024-01-29

Issued to:

**European Safety Systems Ltd
Impress House
Mansell Rd. London W3 7QH
United Kingdom**

This certificate confirms that representative samples of:

NWFN - Auxiliary Devices for Use in Zone Classified Hazardous Locations

See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

UL 60079-1, 7th Ed., Issue Date: 2015-09-18, Revision Date: 2020-01-23, UL 60079-31, Edition: 2, Issue Date: 2015-6-12, Revision Date: 2020-8-13, UL 60079-0, Edition 7, Issued 2019-03-26, Revised 2020-04-15, UL 60079-11, Edition: 6, Issue Date: 2013-02-15, Revision Date: 2023-01-25

Additional Information:

See UL Product iQ® at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



David Piecuch
UL Mark Certification Program Manager



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

CERTIFICATE OF COMPLIANCE

Certificate number UL-US-L513632-352311-42200202-2
Report reference E513632-20200224
Date 2024-01-29

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Model	Product Description
GNExCP7-BG-D	Manual Signalling Box
GNExCP7-BG-D-C	Manual Signalling Box
GNExCP7-BG-D-L	Manual Signalling Box
GNExCP7-BG-I	Manual Signalling Box
GNExCP7-BG-IR	Manual Signalling Box
GNExCP7-BG-S	Manual Signalling Box
GNExCP7-BG-S-C	Manual Signalling Box
GNExCP7-BG-S-L	Manual Signalling Box
GNExCP7-PB-D	Manual Signalling Box
GNExCP7-PB-D-C	Manual Signalling Box
GNExCP7-PB-D-L	Manual Signalling Box
GNExCP7-PB-I	Manual Signalling Box
GNExCP7-PB-IR	Manual Signalling Box
GNExCP7-PB-S	Manual Signalling Box
GNExCP7-PB-S-C	Manual Signalling Box
GNExCP7-PB-S-L	Manual Signalling Box
GNExCP7-PM-D	Manual Signalling Box
GNExCP7-PM-D-C	Manual Signalling Box
GNExCP7-PM-D-L	Manual Signalling Box
GNExCP7-PM-I	Manual Signalling Box
GNExCP7-PM-IR	Manual Signalling Box
GNExCP7-PM-S	Manual Signalling Box
GNExCP7-PM-S-C	Manual Signalling Box
GNExCP7-PM-S-L	Manual Signalling Box
GNExCP7-PT-D	Manual Signalling Box
GNExCP7-PT-D-C	Manual Signalling Box
GNExCP7-PT-D-L	Manual Signalling Box
GNExCP7-PT-I	Manual Signalling Box
GNExCP7-PT-IR	Manual Signalling Box
GNExCP7-PT-S	Manual Signalling Box
GNExCP7-PT-S-C	Manual Signalling Box
GNExCP7-PT-S-L	Manual Signalling Box



David Piecuch
 UL Mark Certification Program Manager

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.



Certificate of Compliance

Certificate Number:

UL-CA-L513632-352611-
42200202-2

Report Reference:

E513632-20200224

Issue Date:

2024-01-29

Issued to:

**European Safety Systems Ltd
Impress House
Mansell Rd. London W3 7QH
United Kingdom**

This certificate confirms that representative samples of:

NWFN7 - Auxiliary Devices for Use in Zone Classified Hazardous Locations Certified for Canada

See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

CSA C22.2 NO. 60079-0:19, 4th Ed., Issue Date: 2019-02-01, CSA C22.2 NO. 60079-1, 3rd Ed., Issue Date: 2016-05-01, CSA C22.2 No. 60079-31, Edition: 2, Issue Date: 2015-10, CSA C22.2 NO. 60079-11:14, 2nd Ed., Issue Date: 2014-02-01

Additional Information:

See UL Product iQ® at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



David Piecuch
UL Mark Certification Program Manager



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

CERTIFICATE OF COMPLIANCE

Certificate number UL-CA-L513632-352611-42200202-2
Report reference E513632-20200224
Date 2024-01-29

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Model	Product Description
GNExCP7-BG-D	Manual Signalling Box
GNExCP7-BG-D-C	Manual Signalling Box
GNExCP7-BG-D-L	Manual Signalling Box
GNExCP7-BG-I	Manual Signalling Box
GNExCP7-BG-IR	Manual Signalling Box
GNExCP7-BG-S	Manual Signalling Box
GNExCP7-BG-S-C	Manual Signalling Box
GNExCP7-BG-S-L	Manual Signalling Box
GNExCP7-PB-D	Manual Signalling Box
GNExCP7-PB-D-C	Manual Signalling Box
GNExCP7-PB-D-L	Manual Signalling Box
GNExCP7-PB-I	Manual Signalling Box
GNExCP7-PB-IR	Manual Signalling Box
GNExCP7-PB-S	Manual Signalling Box
GNExCP7-PB-S-C	Manual Signalling Box
GNExCP7-PB-S-L	Manual Signalling Box
GNExCP7-PM-D	Manual Signalling Box
GNExCP7-PM-D-C	Manual Signalling Box
GNExCP7-PM-D-L	Manual Signalling Box
GNExCP7-PM-I	Manual Signalling Box
GNExCP7-PM-IR	Manual Signalling Box
GNExCP7-PM-S	Manual Signalling Box
GNExCP7-PM-S-C	Manual Signalling Box
GNExCP7-PM-S-L	Manual Signalling Box
GNExCP7-PT-D	Manual Signalling Box
GNExCP7-PT-D-C	Manual Signalling Box
GNExCP7-PT-D-L	Manual Signalling Box
GNExCP7-PT-I	Manual Signalling Box
GNExCP7-PT-IR	Manual Signalling Box
GNExCP7-PT-S	Manual Signalling Box
GNExCP7-PT-S-C	Manual Signalling Box
GNExCP7-PT-S-L	Manual Signalling Box



David Piecuch
UL Mark Certification Program Manager

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.



CERTIFICATE OF COMPLIANCE

Certificate Number UL-CA-2130934-3
Report Reference E508420-20200212
Date 2-Oct-2023

Issued to: European Safety Systems Ltd
Impress House
Mansell Rd.
London W3 7QH
United Kingdom

This is to certify that representative samples of NRNT7 - Switches, Industrial Control Certified for Canada
See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: CSA C22.2 NO. 60947-4-1, 2nd Ed., Issue Date: 2014-04-04, Revised 2018-05

Additional Information: See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.

Deborah Jennings-Conner

Deborah Jennings-Conner, VP Regulatory Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number UL-CA-2130934-3
Report Reference E508420-20200212
Date 2-Oct-2023

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

Model	Category Description
GNEx Series Call Point switches , GNEx CP7, followed by PT, PB, PM or BG, followed by S or D, followed by seven alphanumeric characters, followed by N or L or C.	Industrial Control Switches
STExCP8, followed by PT, PB, PM or BG, followed by S or D, followed by seven alphanumeric characters, followed by N or L or C.	Industrial Control Switches

Deborah Jennings-Conner
Deborah Jennings-Conner, VP Regulatory Services



UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

CERTIFICATE OF COMPLIANCE

Certificate Number UL-US-2135299-3
Report Reference E508420-20200212
Date 2-Oct-2023

Issued to: European Safety Systems Ltd
Impress House
Mansell Rd.
London W3 7QH
United Kingdom

This is to certify that representative samples of NRNT - Switches, Industrial Control
See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 60947-4-1, 3rd Ed., Issue Date: 2014-04-04, Revision Date: 2017-10-17

Additional Information: See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.


Deborah Jennings-Conner, VP Regulatory Services



UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

CERTIFICATE OF COMPLIANCE

Certificate Number UL-US-2135299-3
Report Reference E508420-20200212
Date 2-Oct-2023

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

Model	Category Description
GNEx Series Call Point switches , GNEx CP7, followed by PT, PB, PM or BG, followed by S or D, followed by seven alphanumeric characters, followed by N or L or C.	Industrial Control Switches
STExCP8, followed by PT, PB, PM or BG, followed by S or D, followed by seven alphanumeric characters, followed by N or L or C.	Industrial Control Switches

Deborah Jennings-Conner
Deborah Jennings-Conner, VP Regulatory Services



UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>