



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING & INVESTIGATIONS DIVISION  
BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**

<b>LISTING No.:</b>	7136-2279:0505
<b>CATEGORY:</b>	7136 - AUDIBLE DEVICES FOR HAZARDOUS LOCATIONS
<b>LISTEE:</b>	European Safety Systems LTD Units 18 & 20, Impress House, Mansell Road, Acton, London W3 7QH, GB Contact: King, Alan +44 (0)20 8746 4326 Email: alan.king@e2s.com
<b>DESIGN:</b>	Models E2xL15FR008, E2xL15RR008, E2xL15FR016, E2xL15RR016, E2xL15FR070, E2xL15RR070, E2xL15FR100, E2xL15RR100, E2xL25FR008, E2xL25RR008, E2xL25FR016, E2xL25RR016, E2xL25FR070, E2xL25RR070, E2xL25FR100 and E2xL25RR100 speakers  Models E2xL15UL8ohm, -16ohm, E2xL15UL70V Line, -100V Line, Models E2xL25UL8ohm, -16ohm, E2xL25UL70V Line, -100V Line speakers.  For use in the following Hazardous Locations:  Class I Division 2 Groups A, B, C and D;  Class II Division 2 Groups F and G;  Class I Zone 2 AEx nA IIC Tx Gc;  Zone 22 AEx tc IIIC Tx Dc.  Refer to listee's printed data sheet for additional detailed product description and operational considerations.
<b>RATING:</b>	Refer to listee's printed datasheet for electrical and environmental ratings.
<b>INSTALLATION:</b>	In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.
<b>MARKING:</b>	Listee's name, model number, electrical rating, and UL label.



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING & INVESTIGATIONS DIVISION  
BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**

**APPROVAL:**

Listed as speaker for use in hazardous locations when used with separately listed compatible fire alarm control units. Devices are suitable for outside use.

Refer to Manufacturers Installation Instruction Manual for details.

**NOTES:**

06-07-18 gt



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

**Date Issued: 04/24/2024**

**Listing Expires: 06/30/2025**

Authorized By: **David Castillo**, Program Coordinator  
Fire Engineering & Investigations Division