



# TYPE APPROVAL CERTIFICATE

Certificate no.:  
**TAA00003HR**  
Revision No:  
**1**

## This is to certify:

that the **Fire Technical Ancillary Equipment**

with type designation(s)  
**Visual Alarm Device L101X**

issued to

**European Safety Systems Ltd.**  
London, LO, United Kingdom

is found to comply with

**DNV rules for classification – Ships, offshore units, and high speed and light craft**  
**IEC 60945 Ed. 4 (2002-08) Maritime navigation and radiocommunication equipment and systems – General requirements – Methods of testing and required test results**

## Application:

Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV.

### Location classes:

Temperature	D
Humidity	B
Vibration	A
EMC	B
Enclosure	C / IP66

Issued at **Høvik** on **2025-06-10**

This Certificate is valid until **2030-02-13**.

for **DNV**

DNV local unit: **UK & Ireland CMC & VMC**

Approval Engineer: **Frode Nygård**

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to USD 300 000.

## Product description

The AlertAlight device L101X are UL, cUL, ULC, Type 4/4X, IP66 marine grade, flame-retardant plastic enclosure.

### AlertAlight devices: [a] [volt]

[a]	Type	Product
	L101X	5 Joule Xenon Flash Tube, effective candela 200 cd.
[volt]	Voltage	Voltage Range
	DC024	20 - 28Vdc
	DC048	42 - 54Vdc
	AC115	103,5-126,5Vac
	AC230	207-240Vac

## Place of manufacture

European Safety Systems Ltd.  
Impress House, Mansell Road, Acton,  
London,  
UK  
W3 7QH

## Application/Limitation

Ex-certification is not covered by this certificate. Application in hazardous area to be approved in each case according to Ex-Certification/ Special Condition for Safe Use listed in valid Ex-certificate issued by a notified/recognized Certification Body.

## Approval conditions

The Type Approval covers hardware listed under Product description. When the hardware is used in applications to be classed by DNV, documentation for the actual application is to be submitted for approval by the manufacturer of the application system in each case. Reference is made to DNV rules for classification of ships Pt.4 Ch.9 Control and monitoring systems.

## Type Approval documentation

### Tests carried out

Applicable tests according to:  
- Class guideline DNV-CG-0339, August 2021  
- EN 60945:2002 incl. IEC 60945 Corr.1:2008  
- EN 54-23:2010

### Marking of product

The products to be marked with:  
- manufacturer name  
- item number  
- serial number  
- power supply ratings

### **Periodical assessment**

The scope of the periodical assessment is to verify that the conditions stipulated for the type are complied with, and that no alterations are made to the product design or choice of systems, software versions, components and/or materials.

The main elements of the assessment are:

- Ensure that type approved documentation is available
- Inspection of factory samples, selected at random from the production line (where practicable)
- Review of production and inspection routines, including test records from product sample tests and control routines
- Ensuring that systems, software versions, components and/or materials used comply with type approved documents and/or referenced system, software, component and material specifications
- Review of possible changes in design of systems, software versions, components, materials and/or performance, and make sure that such changes do not affect the type approval given
- Ensuring traceability between manufacturer's product type marking and the type approval certificate

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE